



TYPICAL FLOOR MTD. RACK
SCALE: NONE

TYPICAL WALL MTD. RACK
SCALE: NONE

- NOTES:**
1. DATA COLLECTION CONTROLLER SHALL BE INSTALLED IN LOCATIONS APPROVED BY UW CAMPUS UTILITIES AND OPERATIONS.
 2. CATALOG NUMBERS SHOWN ARE UNISTRUT METAL FRAMING SYSTEMS CHANNEL AND ACCESSORIES. APPROVED EQUAL SYSTEMS MAY BE SUBSTITUTED.
 3. EQUIPMENT RACK MAY BE EXPANDED TO ACCOMMODATE SEVERAL DEVICES AT THE SAME LOCATION, AS INDICATED ON PLAN DWG'S.
 4. ADJUST CROSS FRAME MEMBERS TO SUIT MOUNTING REQUIREMENTS OF EQUIPMENT ENCLOSURES. UTILIZE FRAMING AS CONDUIT SUPPORT AS REQ'D.

REVISIONS		
NO.	BY	DATE

CASNE Engineering
3545 FACTORIA BOULEVARD SE., SUITE 200
BELLEVUE, WA 98006
(425) 522-1000 WWW.CASNE.COM JOB NO. 201-061

PROJECT NAME:
**UNIVERSITY OF WASHINGTON
METER SPECIFICATION UPDATE**

DRAWING TITLE:
**CAMPUS UTILITIES AND OPERATIONS
SECTION 23 09 13.11 DETAIL #2
DATA COLLECTION CONTROLLER MOUNTING**

PROJECT NO. 178979	SCALE N/A	DATE 09/30/20	REVISION NO.
DESIGNED BY: RJJ	CHECKED BY:	DRAWING NO.	
DRAWN BY: EJJ	REVIEWED BY: MJH		

	CAD ID:
	BLDG ID:
	PROJECT NO:
	FILE ID:

DETAIL