

SECTION 06 20 23 - INTERIOR FINISH CARPENTRY

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Interior standing and running trim.
 - 2. Shelving and clothes rods.
- B. See Division 06 Section "Interior Architectural Woodwork" for interior woodwork not specified in this Section.

1.2 SUBMITTALS

- A. Product Data: For each type of process and factory-fabricated product.
- B. Samples: For each type of paneling indicated.
- C. LEED Submittals:
 - 1. Credit EQ 4.1: Manufacturers' product data for adhesives and glues, including printed statement of VOC content.
 - 2. Credit EQ 4.4: Composite wood manufacturer's product data for each composite wood product used indicating that the bonding agent contains no urea formaldehyde.

PART 2 - PRODUCTS

2.1 MATERIALS, GENERAL

- A. Lumber: DOC PS 20 and applicable grading rules of inspection agencies certified by ALSC's Board of Review.
- B. Softwood Plywood: DOC PS 1.
- C. Hardboard: AHA A135.4.
- D. MDF: ANSI A208.2, Grade 130, made with binder containing no urea-formaldehyde resin.
- E. Particleboard: ANSI A208.1, Grade M-2, made with binder containing no urea-formaldehyde resin.

- F. Melamine-Faced Particleboard: Particleboard complying with ANSI A208.1, Grade M-2, finished on both faces with thermally fused, melamine-impregnated decorative paper complying with LMA SAT-1.

2.2 FIRE-RETARDANT-TREATED MATERIALS

- A. Lumber: Comply with performance requirements in AWPAC20, Interior Type A. Kiln dry after treatment to a maximum moisture content of 19 percent.
- B. Plywood: Comply with performance requirements in AWPAC27, Interior Type A. Kiln dry after treatment to a maximum moisture content of 15 percent.
- C. Application: All interior lumber and plywood.

2.3 STANDING AND RUNNING TRIM

- A. Softwood Lumber Trim:
 - 1. Species and Grade: Douglas fir-larch or Douglas fir south, Superior or C & Btr finish; NLGA, WCLIB, or WWPAC.
 - 2. Maximum Moisture Content: 15 percent.
- B. Hardwood Moldings for Transparent Finish (Stain or Clear Finish): WMMPA HWM 2, N-grade wood moldings made to patterns included in WMMPA WM 12.
 - 1. Species: **[Red oak] [White maple]**.
 - 2. Maximum Moisture Content: 9 percent.
- C. Moldings for painted trim:
 - 1. Hardwood moldings as above
 - 2. Optional Material: Primed MDF.

2.4 SHELVING AND CLOTHES RODS

- A. Shelving: Made from one of the following materials, 3/4 inch thick. Do not use particleboard or MDF that contains urea formaldehyde.
 - 1. Particleboard with solid-wood front edge.
 - 2. MDF with solid-wood front edge.
 - 3. Melamine-faced particleboard with applied PVC front edge.
 - 4. Softwood Boards: Douglas fir-larch, Douglas fir south, or hem-fir; **[Superior or C & Btr] [Prime or D]** finish; NLGA, WCLIB, or WWPAC; or southern pine, **[B & B] [C]** finish; SPIB; kiln dried.
- B. Shelf Cleats: 3/4-by-5-1/2-inch boards with hole and notch to receive clothes rods, as specified above for shelving.

- C. Shelf Brackets with Rod Support: BHMA A156.16, B04051; prime-painted formed steel.
- D. Shelf Brackets without Rod Support: BHMA A156.16, B04041; prime-painted formed steel.
- E. Clothes Rods: 1-1/2-inch- diameter, clear, kiln-dried hardwood.

2.5 MISCELLANEOUS MATERIALS

- A. Glue: Aliphatic-resin, polyurethane, or resorcinol wood glue.
 - 1. Use wood glue that has a VOC content of 30 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

PART 3 - EXECUTION

3.1 PREPARATION

- A. Before installing interior finish carpentry, condition materials to average prevailing humidity in installation areas for a minimum of 24 hours.

3.2 INSTALLATION, GENERAL

- A. Install interior finish carpentry level, plumb, true, and aligned with adjacent materials. Use concealed shims where necessary for alignment.
 - 1. Scribe and cut interior finish carpentry to fit adjoining work.
 - 2. Countersink fasteners, fill surface flush, and sand where face fastening is unavoidable.
 - 3. Install to tolerance of 1/8 inch in 96 inches for level and plumb. Install adjoining interior finish carpentry with 1/32-inch maximum offset.
 - 4. Install stairs with no more than 3/16-inch variation between adjacent treads and risers and with no more than 3/8-inch variation between largest and smallest treads and risers within each flight.

3.3 STANDING AND RUNNING TRIM INSTALLATION

- A. Install with minimum number of joints practical, using full-length pieces from maximum lengths of lumber available. Cope at returns and miter at corners to produce tight-fitting joints. Use scarf joints for end-to-end joints.

3.4 SHELVING AND CLOTHES ROD INSTALLATION

- A. Cut shelf cleats at ends of shelves about 1/2 inch less than width of shelves and sand exposed ends smooth.
- B. Install shelf cleats by fastening to framing or backing with finish nails or trim screws, set below face and filled. Space fasteners not more than 16 inches o.c.

- C. Install shelf brackets according to manufacturer's written instructions, spaced not more than 36 inches o.c. Fasten to framing members, blocking, or metal backing, or use toggle bolts or hollow wall anchors.
- D. Cut shelves to neatly fit openings with only enough gap to allow shelves to be removed and reinstalled. Install shelves, fully seated on cleats, brackets, and supports.

END OF SECTION 06 20 23