

SECTION 09 51 13 - ACOUSTICAL PANEL CEILINGS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes acoustical panels and exposed suspension systems for ceilings.

1.2 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Coordination Drawings: Drawn to scale and coordinating acoustical panel ceiling installation with hanger attachment to building structure and ceiling mounted items:
- C. Samples: For each exposed finish.
- D. Product test reports.
- E. Research/evaluation reports.
- F. Maintenance data.
- G. Attic stock: provide 15% overage of both grid system and ceiling panels for University's maintenance stock.

1.3 QUALITY ASSURANCE

- A. Acoustical Testing Agency Qualifications: An independent testing laboratory or an NVLAP-accredited laboratory.
- B. Fire-Test-Response Characteristics:
 - 1. Fire-Resistance Characteristics: Where indicated, provide acoustical panel ceilings identical to those of assemblies tested for fire resistance per ASTM E 119 by UL or another testing and inspecting agency acceptable to authorities having jurisdiction.
 - a. Identify materials with appropriate markings of applicable testing and inspecting agency.
 - 2. Surface-Burning Characteristics: Acoustical panels complying with ASTM E 1264 for Class [A] [B] materials, when tested per ASTM E 84.
 - a. Smoke-Developed Index: 450 or less.

- C. Seismic Standard: Comply with the following:
 - 1. Standard for Ceiling Suspension Systems Requiring Seismic Restraint: Comply with ASTM E 580.
 - 2. ASCE 7, "Minimum Design Loads for Buildings and Other Structures": Section 9, "Earthquake Loads."
- D. Mockups: Build mockups to verify selections made under sample submittals and to demonstrate aesthetic effects and set quality standards for materials and execution.
 - 1. Approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.
- E. Preinstallation Conference: Conduct conference at Project site.

PART 2 - PRODUCTS

2.1 ACOUSTICAL PANEL CEILINGS, GENERAL

- A. Acoustical Panel Standard: Comply with ASTM E 1264.
- B. Metal Suspension System Standard: Comply with ASTM C 635.
- C. Attachment Devices: Size for five times the design load indicated in ASTM C 635, Table 1, "Direct Hung," unless otherwise indicated. Comply with seismic design requirements.
 - 1. Power-Actuated Fasteners in Concrete: Fastener system of type suitable for application indicated, fabricated from corrosion-resistant materials, with clips or other accessory devices for attaching hangers of type indicated, and with capability to sustain, without failure, a load equal to 10 times that imposed by ceiling construction, as determined by testing per ASTM E 1190, conducted by a qualified testing and inspecting agency.
- D. Wire Hangers, Braces, and Ties: Zinc-coated carbon-steel wire; ASTM A 641/A 641M, Class 1 zinc coating, soft temper.
 - 1. Size: Select wire diameter so its stress at 3 times hanger design load (ASTM C 635, Table 1, "Direct Hung") will be less than yield stress of wire, but provide not less than 0.106-inch- diameter wire.
- E. Seismic perimeter stabilizer bars, seismic struts, and seismic clips.
- F. Metal Edge Moldings and Trim: Type and profile indicated or, if not indicated, manufacturer's standard moldings for edges and penetrations that comply with seismic design requirements; formed from sheet metal of same material, finish, and color as that used for exposed flanges of suspension system runners.

2.2 ACOUSTICAL PANELS FOR ACOUSTICAL PANEL CEILING

- A. Products: Subject to compliance with requirements, provide one of the following:
1. Armstrong World Industries, Inc.; <Insert product name or designation>.
 2. Chicago Metallic Corporation; <Insert product name or designation>.
 3. Ecophon CertainTeed, Inc.; <Insert product name or designation>.
 4. USG Interiors, Inc.; <Insert product name or designation>.
- B. Color: [**White**] [**As indicated in a schedule**].
- C. LR: Not less than <Insert LR>.
- D. NRC: Not less than <Insert NRC>, Type E-400 mounting per ASTM E 795.
- E. CAC: Not less than <Insert CAC>.
- F. AC: Not less than <Insert AC>.
- G. Edge/Joint Detail: [**Square**] [Tegular].
- H. Thickness: [**5/8 inch**] [**3/4 inch**].
- I. Modular Size: [**24 by 24 inches**] [**24 by 48 inches**]

2.3 METAL SUSPENSION SYSTEM FOR ACOUSTICAL PANEL CEILING <

- A. Products: Subject to compliance with requirements, provide one of the following:
1. Armstrong World Industries, Inc.; <Insert product name or designation>.
 2. Chicago Metallic Corporation; <Insert product name or designation>.
 3. Ecophon CertainTeed, Inc.; <Insert product name or designation>.
 4. USG Interiors, Inc.; <Insert product name or designation>.
 5. <Insert manufacturer's name; product name or designation.>
- B. Double-Web, Steel Suspension System: Main and cross runners roll formed from cold-rolled steel sheet, prepainted, [**electrolytically zinc coated**], or [**hot-dip galvanized**] according to ASTM A 653/A 653M, not less than G30 coating designation, with prefinished [**15/16-inch-**] [**9/16-inch-**] wide metal caps on flanges.
1. Structural Classification: Intermediate -duty system.
 2. End Condition of Cross Runners: Override (stepped) or butt-edge type.
 3. Cap Material: Steel or aluminum cold-rolled sheet.
 4. Cap Finish: Painted white.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Comply with ASTM C 636 and seismic design requirements indicated, per manufacturer's written instructions and CISCA's "Ceiling Systems Handbook."
- B. Measure each ceiling area and establish layout of acoustical panels to balance border widths at opposite edges of each ceiling. Avoid using less-than-half-width panels at borders.
- C. Suspend ceiling hangers from building's structural members, plumb and free from contact with insulation or other objects within ceiling plenum. Splay hangers only where required and, if permitted with fire-resistance-rated ceilings, to miss obstructions; offset resulting horizontal forces by bracing, countersplaying, or other equally effective means. Where width of ducts and other construction within ceiling plenum produces hanger spacings that interfere with location of hangers, use trapezes or equivalent devices. When steel framing does not permit installation of hanger wires at spacing required, install carrying channels or other supplemental support for attachment of hanger wires.
 - 1. Do not support ceilings directly from permanent metal forms or floor deck; anchor into concrete slabs.
 - 2. Do not attach hangers to steel deck tabs or to steel roof deck.
- D. Install edge moldings and trim of type indicated at perimeter of acoustical ceiling area and where necessary to conceal edges of acoustical panels. Screw attach moldings to substrate at intervals not more than 16 inches o.c. and not more than 3 inches from ends, leveling with ceiling suspension system to a tolerance of 1/8 inch in 12 feet. Miter corners accurately and connect securely.
- E. Install suspension system runners so they are square and securely interlocked with one another. Remove and replace dented, bent, or kinked members.
- F. Install acoustical panels with undamaged edges and fit accurately into suspension system runners and edge moldings. Scribe and cut panels at borders and penetrations to provide a neat, precise fit.

END OF SECTION 09 51 13